

REPLIES TO PRE BID QUERIES LOT 4 DATED 13.02.2024
NIT NO : PNMM/PC 183/E 4024/NCB DATED 12.01.2024
SUB : CONSTRUCTION OF 220 KV LILO GIS AT TALCHER FERTILIZERS LIMITED

S.No	Reference Document	Reference Clause/DocNo.	Technical Issue	Customer's Requirement	Clarification	PDIL Reply
1	Technical Specification	Technical Specifications (Part-3; 220/33kV 20 MVA Power Transformer)	NIFPS	N/A	In the specification for TR- NIFPS specification is striked off. In BOQ also NIFPS is not mentioned. Hence we understand that NIFPS need not to be supplied. Kindy confirm our understanding.	Bidder's understanding in this regard is correct as NIFPS is not envisaged. Provision of the Tender document, read along with the Price Schedule, are amply clear in this regard.