

PROJECT : COAL GASIFICATION BASED FERTILISER PLANT AT TALCHER, ODISHA
NIT No. ; PNMM/PC-183/E- 4016/NCB Dated 15.07.2022 INSTRUMENT AIR & PLANT AIR SYSTEM
SUBJECT : REPLY TO PRE-BID QUERIES : LOT 3 Dated 01.09.2022

SL. NO.	REFERENCE OF BIDDING DOCUMENT				Bidders Queries/clarificatiois	PDIL/TFL's Reply
	SEC. NO.	PAGE NO.	CLAUSE NO.	SUBJECT		
1	DESIGN PHILOSOPHY – PIPING; (Doc. No. EM0000-PNMP-TS951. Rev.0)	Page 6 of 45	Cl. No. 3.3; (ii)	Fire protection system shall be designed and installed in accordance with applicable NFPA (National Fire Protections Associations) Codes	As nothing is mentioned in the Scope of work, we understand that Fire Protection System including fire water line is not in Bidder's Scope. Please confirm.	<p>Spray, sprinkler and fire hydrant systems of IA/PA package are in the scope of separate NIT.</p> <p>Bidder shall provide following items as per TAC/NFPA for this NIT.</p> <p>Sand bucket, fire extinguisher (CO2 type and DCP type extinguishers (MAP 90% ABC UL listed powder, BIS approved) and Personal protective equipments (PPE)</p> <p>a) Safety helmets – 05 nos.</p> <p>b) Stretcher (Heavy duty Aluminium, BIS mark) – 01 no.</p> <p>c) Fibre glass First Aid Box with all necessary items/kit & anti snake serum -02 sets.</p> <p>d) Rubber hand gloves for electrical jobs- 05 pairs.</p> <p>e) Hand held battery loaded Emergency light, each with 1 set spare battery- 02 nos</p>
2	General			FDA/HVAC System	As nothing is mentioned in the Scope of work, we understand that FDA/HVAC are not in Bidder's Scope. Please confirm.	We confirm that HVAC system is not in Bidder's scope.