

PDIL NIT NO : PNMM/PC-183/E- 4008/NCB

Item:INSTRUMENT AIR & PLANT AIR SYSTEM

REPLIES TO PRE BID QUERIES -LOT- 7 DATE 14.07.2021

Pre Bid Comments on PDIL/TFL

Sr. No.	Document number	Document Title	Clause No./ Line	Page No.	Technical Requirement	Deviation / Clarification	PDIL/TFL Reply	Deviation /	PDIL/TFL Reply
1	INVITATION FOR BID (IFB)	SECTION-II BID EVALUATION CRITERIA	1.2	13 of 959	Technical criteria: "Similar Work" means Design Engineering, Supply, Installation and Testing & Commissioning of at least One Instrument Air & Plant Air System	Please advise whether Similar work should also meet design criteria API 672 for meeting technical criteria or Non API machine can also be furnished for this criteria.	As per API 672	Noted	Similar work "means" under bid evaluation criteria as per Clause 1.1 & 1.2, Section-II, as per NIT. "Similar Work" means Design Engineering, Supply, Installation and Testing & Commissioning of at least One Instrument Air & Plant Air System of Design capacity of minimum 8000 Nm3/hr under single stream (or multiple streams of minimum 4000 Nm3/hr capacity each) including supply of Integrally Geared centrifugal Air compressor with capacity of at least 4000 Nm3/hr. It is further clarified that intergearally geared compressor may follow either API 672/ Non API standard for this bid evaluation criteria. Point closed