

Reply of Pre Bid Queries (Lot-1)_22.07.2022

NIT No. PNP/PC0183/E/206/NCB dt. 15.06.2022

Subject Supply & Construction of Ash Pond and Allied Services at Talcher Fertilizer Ltd., Angul

Sl.No	REFERENCE OF TENDER DOCUMENT				Bidders Query	OWNER Reply	
	SECTION NO.	Reply of Pre Bid Queries (Lot-	CLAUSE NO	SUBJECT			Description as in Tender Specification
1						Design and engineering in contractor scope or client . If in contracto's then speedy approval needed or else delay shall count in project delay from client side	Detail engg. is in Contractor's scope. However, it is imperative on Contractor's part to submit the documents/drawings conforming to basic requirements and acceptable design for getting approval.
2						The project completion time is 15 months, and it may extend due to reasons not attributable to bidder, hence,price escalation should be there as markest is very fluctuating	Bidder to quote firm price for entire completion period including extension, if any. No price escalation shall be allowed
3						Cement, steel vendors should be increased as very limited suppliers are available	Vendor list shall be as per NIT.
4						Clarifiers and other mechanical vendors need to be mentioned	If vendor list is not available in NIT, same shall be approved after award of job, subject to meeting technical requirement by supplier.
5				Transformer		Kindly provide us the Technical specification PC183-TS-0802 (mentioned in SOR) for transformer. Also provide us the vendor list for 1 MVA transformer.	PC183-TS-0802 shall be read as PC183-TS-0803. Refer Page 1166 of 1356 of NIT.
6				HT Switch board		Kindly provide us the Vendor list for 11 KV Switch Board.	Vendor for 11 kV Switchboard : a. ABB Ltd b. Crompton Greaves Ltd c. Siemens Ltd d. BHEL (Electrical Machines Divn.) e. Schneider Electric
7				Pressurization System		Kindly provide us the vendor list for Pressurization System.	Vendor for Pressurization System : a. Aerovent Projects Pvt. Ltd. b. C. Doctor India Pvt. Ltd. c. S K Systems Private Ltd. d. Advance Ventilation
8				Design and engineering works		Bidder understands that the tender is item rate tender. Design and Engineering will be the scope of M/s PDIL.	Detailed engineering shall be in scope of Bidder.