

REPLIES TO PRE BID QUERIES LOT-4 DATED - 21.04.2023

NIT NO : PNMM/PC-183/E- 4020/NCB DATED 16.03.2023

SUB : SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF FLARE SYSTEM ON PACKAGE BASIS AT TFL

S.NO.	SECTION NO.	PAGE NO.	CLAUSE NO.	SUBJECT	PRE BID CLARIFICATIONS	PDIL REPLY
1	Technical Specification for Supply, Installation, Testing & Commissioning of Flare System (Document No.: PC183-E-4020-SEC VI)	363 (18 of 33)	4.0 (m)	Dispersion analysis	For the required dispersion analysis, please confirm the software to be used. Please also confirm the allowable limit for pollutants/ toxic gases like HCN to be considered for dispersion analysis.	PHAST Risk Safeti or Aermod view software may be used for dispersion modeling/analysis. The limiting concentration (unless stated) from stack emission for HCN as CN is 5 mg/m3.