



प्रोजेक्ट्स एण्ड डेवलपमेंट इण्डिया लिमिटेड  
(भारत सरकार का उपक्रम) : मिनी रत्न-1 कंपनी  
**Projects & Development India Limited**  
(A Govt. of India Undertaking) : A Mini Ratna-1 Company  
PDIL Bhawan, A-14, Sector-1, NOIDA-201 301  
Distt. Gautam Budh Nagar, (U.P.), India  
CIN : U74140UP1978GOI028629

ISO 9001:2015 & OHSAS 18001:2007 Certified  
and  
ISO/IEC 17020:2012 Accredited  
Date: 09.03.2020

**AMENDMENT-V dated 09.03.2020**  
**to NIT No. PNPM/PC-150/E/111/NCB dated 04.02.2020**

**PROJECT: NIT FOR SUPPLY, ERECTION, TESTING & COMMISSIONING OF  
PERMANENT RAW WATER SUPPLY SYSTEM AT TALCHER  
FERTILIZERS LTD., ANGUL, ODISHA**

Dear Sir's

Please find attached herewith the Amendment No.-V dated 09.03.2020 to NIT No. PNPM/PC-150/E/111/NCB dated 04.02.2020 for Supply, Erection, Testing & Commissioning of Permanent Raw Water Supply System at Talcher Fertilizers Limited, Odisha

All other terms and conditions of NIT and subsequent Amendment(s) shall remain unchanged.

R. R. Kumar  
A.G.M.(Projects)



**NIT FOR SUPPLY, ERECTION, TESTING & COMMISSIONING OF PERMANENT  
RAW WATER SUPPLY SYSTEM AT TALCHER FERTILIZERS LTD., ANGUL, ODISHA  
(ITB No. PNP/PC-150/E/111/NCB Dt. 04.02.2020)  
AMENDMENT-V dated 09.03.2020**



SL. NO.	Reference of Bidding Document			Amendment Type M/D/A/C	MODIFICATION
	Section	Clause No. / Attachment	Description as per NIT/ Amendment		
1.	SEC VI-1.0	<b>Clause 3.0</b> (Page No. 255)	<u>Sl. No. 41 of Amendment-II dated 07.03.2020</u> Revised Pump Discharge pressure- <b>14</b> Kg/cm <sup>2</sup> g & Estimated absorbed power- <b>611</b> Kwh/h per pump (Considering 75% efficiency of pump) Please refer to attachment.	M	Pump Discharge pressure- <b>15</b> Kg/cm <sup>2</sup> g & Estimated absorbed power- <b>655</b> Kwh/h per pump (Considering 75% efficiency of pump) <del>Please refer to attachment.</del>
2.	Section-VI-1.1	<b>Clause No. 1</b> (Page No. 2 of 4)	<u>Sl. No. 45 of Amendment-II dated 07.03.2020</u> <b>Design Philosophy Process:-</b> <b>To be modified as ....</b> Pump Discharge pressure = <b>14</b> Kg/cm <sup>2</sup> g (Pump discharge pressure may vary up to +20% and shall be finalized after root survey finalization)	M	Pump Discharge pressure = <b>15</b> Kg/cm <sup>2</sup> g ( <del>Pump discharge pressure may vary up to +20% and shall be finalized after root survey finalization</del> )
3.	Section-VI-1.1	<b>Clause No. 1</b> (Page No. 2 of 4)	<u>Sl. No. 46 of Amendment-II dated 07.03.2020</u> <b>Design Philosophy Process:-</b> Estimated absorbed power = <b>611</b> Kwh/h per pump (Considering 75% efficiency of pump)	M	Estimated absorbed power = <b>655</b> Kwh/h per pump (Considering 75% efficiency of pump)
4.	Section-VI-1.1	<b>Clause No. 1</b> (Page No. 2 of 4)	<u>Sl. No. 46 of Amendment-II dated 07.03.2020</u> <b>Design Philosophy Process:-</b> Synopsis: Point No.2	M	3W+1S=4 Numbers Pumps to be considered for supplying raw water from Brahmani River. The capacity of each pump shall be 1200



**NIT FOR SUPPLY, ERECTION, TESTING & COMMISSIONING OF PERMANENT  
RAW WATER SUPPLY SYSTEM AT TALCHER FERTILIZERS LTD., ANGUL, ODISHA  
(ITB No. PNP/PC-150/E/111/NCB Dt. 04.02.2020)  
AMENDMENT-V dated 09.03.2020**



			<b>To be modified as ....</b> 3W+1S=4 Numbers Pumps to be considered for supplying raw water from Brahmni River. The capacity of each pump shall be 1200 m <sup>3</sup> /h. estimated absorbed power of each pump is <b>611</b> Kwh/h considering 75% pump efficiency. Provision for 1 nos. pump of similar capacity shall be kept in the pump house for future requirement.		m <sup>3</sup> /h. estimated absorbed power of each pump is <b>655</b> Kwh/h considering 75% pump efficiency. Provision for 1 nos. pump of similar capacity shall be kept in the pump house for future requirement.
5.	Section-VI-1.1	Page No. 4 of 4	<u>Sl. No. 48 of Amendment-II dated 07.03.2020</u> Refer attached revised Intake well Pump Specification along with P&ID PC150-PNPR-DD-02_Rev.1	D	The CENTRIFUGAL PUMP SPECIFICATION SHEET attached with Annexure-II stands <b>DELETED</b> .  Bidder to follow the Specification Sheet attached with the NIT.

**Note :**

1. Bidder to consider Pump Discharge pressure- **15** Kg/cm<sup>2</sup>g & Estimated absorbed power- **655** Kwh/h per pump irrespective of whatever mentioned elsewhere in the NIT/ Amendment
2. All other Amendments/ Terms & Conditions remain the same.

**LEGEND:**

M: MODIFICATION, A: ADDITION, D: DELETION, C: CLARIFICATION