



प्रोजेक्ट्स एण्ड डेवलपमेंट इण्डिया लिमिटेड  
(भारत सरकार का उपक्रम) : मिनी रत्न-1 कंपनी

**Projects & Development India Limited**

(A Govt. of India Undertaking) : A Mini Ratna-1 Company

PDIL Bhawan, A-14, Sector-1, NOIDA-201 301

Distt. Gautam Budh Nagar, (U.P.), India

CIN : U74140UP1978GOI028629

ISO 9001:2015 & OHSAS 18001:2007 Certified

and

ISO/IEC 17020:2012 Accredited

Date: 11.03.2020

**AMENDMENT-VI dated 11.03.2020**  
**to NIT No. PNP/PC-150/E/111/NCB dated 04.02.2020**

**PROJECT: NIT FOR SUPPLY, ERECTION, TESTING & COMMISSIONING OF  
PERMANENT RAW WATER SUPPLY SYSTEM AT TALCHER  
FERTILIZERS LTD., ANGUL, ODISHA**

Dear Sir's

Please find attached herewith the Amendment No.-VI dated 11.03.2020 to NIT No. PNP/PC-150/E/111/NCB dated 04.02.2020 for Supply, Erection, Testing & Commissioning of Permanent Raw Water Supply System at Talcher Fertilizers Limited, Odisha

All other terms and conditions of NIT and subsequent Amendment(s) shall remain unchanged.

R. R. Kumar  
A.G.M.(Projects)

**Regd. Office :- PDIL Bhawan, A-14, Sector-1, Noida-201301**

Phone : +91 - 120 -2529842/43/47/51 Fax : +91 - 120 - 2529801, 2541493

E-mail : noida@pdilin.com

Other Offices : Sindri, Vadodara, Mumbai, Kolkata, Chennai, Hyderabad

Visit us at : www.pdilin.com



**NIT FOR SUPPLY, ERECTION, TESTING & COMMISSIONING OF PERMANENT  
RAW WATER SUPPLY SYSTEM AT TALCHER FERTILIZERS LTD., ANGUL, ODISHA  
(ITB No. PNP/PC-150/E/111/NCB Dt. 04.02.2020)  
AMENDMENT-VI dated 11.03.2020**



SL. NO.	Reference of Bidding Document			Amendment Type M/D/A/C	MODIFICATION
	Section	Clause No. / Attachment	Description as per NIT/ Amendment		
1.	Section-VI-1.1	PC 150-PNPR-DD-02, Rev. 0	<u>Centrifugal Pump Specification Sheet</u> Note : ## Pump discharge pressure may vary up to +20% and shall be finalized after root survey finalization.	C/ D	It is clarified that :  Bidder to follow the Specification Sheet attached with the NIT as already intimated vide Amendment – V dated 09.03.2020,  <u>However, the following note stands DELETED in PC 150-PNPR-DD-02, Rev. 0:</u> <i>## Pump discharge pressure may vary up to +20% and shall be finalized after root survey finalization.</i>

LEGEND:

M: MODIFICATION, A: ADDITION, D: DELETION, C: CLARIFICATION