

**Reply of PRE BID Query LOT-1 dt. 31.07.2023**

**BALANCE ELECTRICAL WORKS (SUPPLY & ERECTION) FOR PLANT LIGHTING AT TALCHER FERTILIZERS LTD., ANGUL, ODISHA**

**NIT NO. : PNPM/PC-183/E-8005/NCB DATED 18.07.2023**

Sr. no.	Reference of Bidding Document			Short Description of Query	Bidder's Query	PDIL Reply
	Document No.	Page No.	Clause No.			
<b>1</b>					As per List of make Annexure-B High Mast: Bajaj Electrical Ltd./ Philips India Ltd. is given in tender. M/s Philips India Ltd. is not having own manufacturing facility. Kindly add some other Manufacturer i.e . Cropton /Utkarsh/Valmont	Vendor List of NIT to be followed.
<b>2</b>					SOR Item no. 6.0 : Supply, storage at site, handling, erection, transportation from store to site of installation, installation, testing and commissioning of flameproof/weather proof (IP-65) distribution board suitable for wall /structure mounting, Outdoor type and the same shall be suitable for DIN rail mounting MCBs/MCCBs/RCCBs etc But sub Item No. 6.01 & 6.02 it is weather proof. Please confirm it is Flameproof/weather proof or Weather proof.	Distribution Boards shall be Weatherproof.
<b>3</b>					Make of Floor mounting Type Distribution Board: due to small Size & Quantity. The approved make vendors given in tender documents are not responding. Please consider CPRI approved manufacturer as per specification and approved make switchgear/components.	Vendor List of NIT to be followed.